



Certificate of Compliance

Certificate: 2468885 (LR77078)

Master Contract: 177618

Project: 2468885

Date Issued: February 10, 2012

Issued to: Heinzmann GmbH & Co. KG

Am Haselbach 1
Schönau im Schwarzwald, Baden-Wurttemberg 79677
Germany
Attention: Ronny Gränz

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Jay McVeigh

Issued by: Jay McVeigh

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

Class I, Division 2, Group A, B, C and D: T4A, Tamb 80°C, IP 20

Ariadne; knock control system; rated 16 to 36Vdc or 12/24Vdc battery operation; 1 Amp maximum

APPLICABLE REQUIREMENTS

CSA C22.2 No 0 - 10	-	General Requirements - Canadian Electrical Code Part II
CSA C22.2 No 0.4 - 04	-	Bonding of Electrical Equipment
CSA Standard C22.2 No. 142-1987	-	Process Control Equipment
CSA C22.2 No 213 - M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations



Certificate: 2468885 (LR77078)

Master Contract: 177618

Project: 2468885

Date Issued: February 10, 2012

CAN/CSA-C22.2 No. 60529:05	-	Degrees of protection provided by enclosures (IP Code)
ANSI/UL Standard 508 – 17th Ed	-	Industrial Control Equipment
ISA 12.12.01: 2007	-	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations